

Bancroft dpw report.

- Arsenic testing results under 2
- Plowed snow 3 to 4 inch
- Salting street to bare minimum. But making them safe for travel.
- Daily water plant testing
- worked a little on community hall
- Cleaned some equipment / Trucks
- Worked on MORs
- Fixed broken chlorine line at water plant.
- 

Thank you  
Mike